



Nestle (Mt Sterling, KY)

CheckList Information

Name : EF-L5 PACK MEZZ **Status :** NotSubmitted
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	0.75HP 1800RPM 460V 1.6A Never witnessed fan running
Make, Model, and Serial Number:	Make: Hartzell Model: 61-24-NG3 Serial: 950550-03A
Attach picture of asset.	Yes
• Open File.jpg	
Fan CFM:	0
Fan total pressure recorded.	
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA