



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-81 / L4 SHEETING WASHDOWN	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Unit not running from switch with disconnect on.
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	
When is fan used (application) and any specific time?	Fan is supposed to be used with L4 washdown cycle and has a manual switch to turn the fan on when required, but the fan does not run when switch is on. maintenance needs to fix
Make, Model, and Serial Number:	CUBE-099-3-X 14703672 L4 BALDOR 2 HP 460V 2.9A 1755RPM
Fan CFM:	