



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-17-06 / L4/5/6 OVEN AREAS	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No noticeable issues. Motor: BALDOR 7.5hp 460 10.1A Cfm: 2310 Sp: -0.47"
Make, Model, and Serial Number:	GREENHECK TB1-FS-4H24-75 07K04450
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	Oven
When is fan used (application) and any specific time?	24/7