



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name :	FF 3,7-93 L4/5 pack mezz, maint shop east	Organization :	FF 3,7-93 L4/5 pack mezz, maint shop east
Status :	Open	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Tyler Youells
Open :	05/12/2021 - Tyler Youells - National TAB	Description:	3-93 disconnect is on but schedule indicates a capped curb. 7-93 disconnect is off and schedule indicates a capped curb. Are these fans abandoned?

Project RFI File Details

- 1. [Open](#) File.jpg
- 2. [Open](#) File(1).jpg

Project RFI Response Details

- **05/20/2021** **National TAB - JOE HERTENSTEIN**
 - Serves Maintenance shop & manually turned on with EF5-93 when warmer season for ventilation.