



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name : MAU 10-93 L4/5/6 OVEN AREAS **Organization :** MAU 10-93 L4/5/6 OVEN AREAS
Status : Open **Assigned To :** National TAB - JOE HERTENSTEIN
Shared To : **Created :** Tyler Youells
Open : 05/12/2021 - Tyler Youells - National TAB **Description:** Unit is not running. Disconnect is off. Unit appears to have run in a long time. Does the unit plan to be utilized? Unit is on schedule.

Project RFI File Details

- 1. [Open](#) File.jpg

Project RFI Response Details

- **05/27/2021** **National TAB - JOE HERTENSTEIN**
 - Unit is design to supply 30,000 CFM to oven room. Not operational causing impact to building. MUA7-96 is the other MUA in the oven rooms not running design for 40,000 CFM.