



Nestle (Mt Sterling, KY)

CheckList Information

Name : EF-52 / SANITATION TANKS - L8 SPIRAL FREEZER/OVEN **Status :** NotSubmitted
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Not safe to access motor while running Could not access duct to perform traverse with lift. Ductwork is far above the max height of lift onsite. Make:Greenheck Model:RBUH0-3H48-75 Serial:Q4125622
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA
Make, Model, and Serial Number:	Make:Greenheck Model:RBUH0-3H48-75 Serial:04125622 Sp:1.15
Fan CFM:	unable to measure