



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	SF-L8	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fan runs for emergency use only Belt is loose
Make, Model, and Serial Number:	Make:Greenheck Model:R8F-2H42-50 Serial:11600758
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan CFM:	NA
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	Freezer room
When is fan used (application) and any specific time?	Freezer room