



Nestle (Mt Sterling, KY)

CheckList Information

Name :	FF-3-93 EAST MAINTENANCE	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fans do not run
Make, Model, and Serial Number:	Make: Hartzell Model: 16 36 LK3 Serial: 9302560 Unit Data: 3HP 460V 4.3A 1800 RPM
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	0
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA