



Nestle (Mt Sterling, KY)

CheckList Information

| | | | |
|----------------------------------|-----------------------------|-----------------|--------------|
| Name : | EF-2-11 / WEST LAB & OFFICE | Status : | NotSubmitted |
| Assigned Organization : | National TAB | Asset : | |
| Requesting Organization : | National TAB | | |

CheckList Item Details

| | |
|--|---|
| Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops. | Make:Greenheck Model:6-070-D Serial: 12089423 FASCO motor 1/30HP 1.1A 115V 1550RPM Does not run |
| Attach picture of asset. | Yes |
| <ul style="list-style-type: none"> • Open File.jpg | |
| Fan total pressure recorded. | No |
| Is Fan interlocked with any other asset? if so, list: | NA |
| When is fan used (application) and any specific time? | NA |
| Make, Model, and Serial Number: | Make:Greenheck Model:6-070-D Serial: 12089423 FASCO motor 1/30HP 1.1A 115V 1550RPM |
| Fan CFM: | Does not run |