



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-16-06 / L4/5/6 OVEN AREAS	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	NO ISSUES
Make, Model, and Serial Number:	GREENHECK, RBUMO-2H30-15, 07F07683
Attach picture of asset.	Yes
Fan CFM:	8269 CFM Sp: -0.333"
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	NO
When is fan used (application) and any specific time?	USED FOR OVEN ROOM VENTILATION. 24/7