



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name :	MAU 7-96 L6/8 OVEN AREAS	Organization :	MAU 7-96 L6/8 OVEN AREAS
Status :	Pending	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Tyler Youells
Open :	05/12/2021 - Tyler Youells - National TAB	Description:	Unit is not running. Disconnect is locked out and off. Unit is in very poor physical condition with tarp falling off that was covering the intake. Unit is on the schedule.

Project RFI File Details

1. [Open](#) File.jpg

Project RFI Response Details

- **05/27/2021** **National TAB - JOE HERTENSTEIN**
 - FACILITIES TEAM TO REVIEW FOR MAINTENANCE-IN PROCESS OF CHANGING OUT PARTS
- **05/19/2021** **National TAB - Alec Lewis**
 - Should be running, but not currently working. They have parts in the shop but have not had time to fix it.