



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-26-96 / L6 OVEN	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No visual issues
Make, Model, and Serial Number:	Unit data NYB Shop number: P17739-100 182 PLR Motor 460 10A Hp NL
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	Vel: 587 10" Cfm 323
Fan total pressure recorded.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Is Fan interlocked with any other asset? if so, list:	L6 oven
When is fan used (application) and any specific time?	L6 oven