



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-10-93 / STOCKROOM	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Unit is noisy sits above a desk they usually leave it off because of it. Unit data: Hartzell 69-12-WG3 9302560-05 0.75 HP 460 1.5A cfm: 3042 Discharge pressure:0.0564"
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	No switch is in the oven mezz
When is fan used (application) and any specific time?	Rarely used due to the noise.