



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-10-93 / STOCKROOM	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Unit is noisy sits above a desk they usually leave it off because of it.
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	No switch is in the oven mezz
When is fan used (application) and any specific time?	Rarely used due to the noise.
Make, Model, and Serial Number:	Unit data: Hartzell 69-12-WG3 9302560-05 0.75 HP 460 1.5A
Fan CFM:	cfm: 3042 Discharge pressure:0.0564"