

EXHAUST FANS SCHEDULE - PART 2 OF 2

TYPICAL DESIGN CONDITIONS:

SUMMER = 91°F / 74°F

WINTER = 7°F

UNIT NO.	SERVICE AREA	YEAR INSTALLED	MANUFACTURER	MODEL NO.	SERIAL NO.	NESTLÉ TAG NO.	ELECTRICAL							MECHANICAL										NOTES		
							VOLT	HZ	PH	FLA	MCA	MOP	HP	RPM	TYPE	AIRFLOW (CFM)	STATIC PRESSURE EXTERNAL (IN. W.C.)	TOTAL (IN. W.C.)	FAN TYPE	FAN RPM	MOTOR TYPE	DRIVE	SOUND POWER (SONES)		OPERATING WEIGHT (LBS.)	ROOF OPENING (IN. X IN.)
EF-54	LINE 8 PACKAGING	2004	GREENHECK	CUBE-161-7	-	-	115	60	1	-	-	-	0.75	-	UPBLAST	3,333	0.32	-	VERTICAL	-	PROP.	BD	-	200	18½x18½	ROOF MOUNTED. DUCTWORK IN MEZZ HAS BEEN CUT & CAPPED. NOT IN USE.
EF-55	LINE 8 PACKAGING	2004	GREENHECK	CUBE-161-7	-	-	115	60	1	-	-	-	0.75	-	UPBLAST	3,333	0.32	-	VERTICAL	-	PROP.	BD	-	200	18½x18½	ROOF MOUNTED. DUCTWORK IN MEZZ HAS BEEN CUT & CAPPED. NOT IN USE.
EF-56	LINE 8 PACKAGING	2004	GREENHECK	CUBE-161-7	-	-	115	60	1	-	-	-	0.75	-	UPBLAST	3,333	0.32	-	VERTICAL	-	PROP.	BD	-	200	18½x18½	ROOF MOUNTED. DUCTWORK IN MEZZ HAS BEEN CUT & CAPPED. NOT IN USE.
EF-57	LOCKER ROOMS	2004	GREENHECK	G-101-A	-	-	115	60	1	-	-	-	0.25	-	CENTRI.	860	0.6	-	VERTICAL	-	-	DD	-	150	14½x14½	ROOF MOUNTED. FAN TO RUN CONTINUOUSLY.
EF-58	REAR OFFICE RESTROOMS	2004	GREENHECK	G-095-D	-	-	115	60	1	-	-	-	0.125	-	CENTRI.	675	0.4	-	VERTICAL	-	-	DD	-	150	12½x12½	ROOF MOUNTED. FAN TO RUN CONTINUOUSLY.
EF-59	BOILER ROOM	2004	GREENHECK	RBU-2L30-20	-	-	480	60	3	-	-	-	2	-	UPBLAST	12,000	0.125	-	VERTICAL	-	PROP.	BD	-	350	36x36	ROOF MOUNTED. INTERLOCK WITH SF-1-04.
EF-60	THERMAL OIL HEATING ROOM @ PROOFER ROOM	2004	GREENHECK	CWB-101-4	-	-	115	60	1	-	-	-	0.25	-	-	1,050	0.5	-	HORIZ.	-	PROP.	BD	-	100	-	THERMOSTAT ON WALL. MOUNT FAN 8'-0" A.F.F.
EF-61	LINE 8 OVEN #1 INFEEED HOOD EXH.	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	2,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-62	LINE 8 OVEN #1 STEAM SECTION	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-63	LINE 8 OVEN #1 EVACUATION ZONE	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,000	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-64	LINE 8 OVEN #1 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-65	LINE 8 OVEN #1 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-66	LINE 8 OVEN #1 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-67	LINE 8 OVEN #1 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-68	LINE 8 OVEN #1 DISCHARGE HOOD	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,000	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-69	LINE 8 OVEN #2 INFEEED HOOD EXH.	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	2,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-70	LINE 8 OVEN #2 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-71	LINE 8 OVEN #2 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-72	LINE 8 OVEN #2 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-73	LINE 8 OVEN #2 ZONE COMBUSTION EXHAUSTS	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,500	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-74	LINE 8 OVEN #2 DISCHARGE HOOD	2004	NEW YORK BLOWER	IM-150	-	-	460	60	3	-	-	-	3	-	CENTRI.	1,000	5	-	VERTICAL	-	-	BD	-	-	Ø10" STACK	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-16-06	LINES 4/5/6 OVEN AREAS	2006	GREENHECK	RBUMO-2H30-15	-	-	-	-	-	-	-	-	1.5	-	UPBLAST	8613 9153	0.375	-	VERTICAL	-	PROP.	BD	-	350	39½x39½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-17-06	LINES 4/5/6 OVEN AREAS	2006	GREENHECK	RBUMO-2H30-15	-	-	-	-	-	-	-	-	1.5	-	UPBLAST	8613 9153	0.375	-	VERTICAL	-	PROP.	BD	-	350	39½x39½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-18-06	LINES 4/5/6 OVEN AREAS	2006	GREENHECK	RBUMO-2H30-15	-	-	-	-	-	-	-	-	1.5	-	UPBLAST	8613 9153	0.375	-	VERTICAL	-	PROP.	BD	-	350	39½x39½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-19-06	LINES 4/5/6 OVEN AREAS	2006	GREENHECK	RBUMO-2H30-15	-	-	-	-	-	-	-	-	1.5	-	UPBLAST	8613 9153	0.375	-	VERTICAL	-	PROP.	BD	-	350	39½x39½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-22-06	L4 OVEN EXHAUST STACK	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	2,000	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-23-06	L4 OVEN EXHAUST STACK	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	2,000	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-24-06	L4 OVEN EXHAUST STACK	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	2,000	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-25-06	L4 OVEN EXHAUST STACK	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	2,000	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-26-06	L4 OVEN EXHAUST STACK	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	2,000	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-27-06	LINE 4 OVEN INFEEED HOOD	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	3,600	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-28-06	LINE 4 OVEN DISCHARGE HOOD	2006	NEW YORK BLOWER	SERIES 20 GI FAN SIZE 174 LS	-	-	460	60	3	-	-	-	-	CENTRI.	2,000	-	-	VERTICAL	-	PROP.	-	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-29-06	LINES 4/5/6 OVEN MEZZANINE	2006	GREENHECK	RBUMO-3L36-50	-	-	-	-	-	-	-	-	5	-	UPBLAST	18230 19334	0.5	-	VERTICAL	-	PROP.	BD	-	450	45½x45½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-30-06	LINES 4/5/6 OVEN MEZZANINE	2006	GREENHECK	RBUMO-3L36-50	-	-	-	-	-	-	-	-	5	-	UPBLAST	18230 19334	0.5	-	VERTICAL	-	PROP.	BD	-	450	45½x45½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-31-06	LINES 4/5/6 OVEN MEZZANINE	2006	GREENHECK	RBUMO-3L36-50	-	-	-	-	-	-	-	-	5	-	UPBLAST	18230 19334	0.5	-	VERTICAL	-	PROP.	BD	-	450	45½x45½	ON THE OVEN ROOF. INSUFFICIENT ELECTRICAL DATA.
EF-6-08	LOCKER, TOILETS & AIR TUNNEL AREAS	2008	LOREN COOK	180 AGE 18005B	0635932274/00/000070	-	-	-	-	-	-	-	0.5	-	UPBLAST	2,400	-	-	VERTICAL	-	PROP.	-	-	-	-	PREVIOUSLY EF-6-93. LOCATED ON THE FRONT OFFICE ROOF UNDER THE PENTHOUSE FOR GMAs 24 & 25.
EF-7-08	LINE 6 OVEN INFEEED HOOD EXHAUST	2008	GREENHECK	TBI-FS-4H24-75	07K04450	-	-	-	-	-	-	-	-	AXIAL UPBLAST	2,708 @ 400F	-	-	VERTICAL	-	-	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP. PREVIOUSLY EF-1 OR EF-HOPE.
EF-8-08	LINE 6 OVEN INFEEED ROOM EXHAUST	2008	HARTZELL	70-42-WL3	-	-	230/ 460	60	3	-	-	-	5	-	CENTRI. UPBLAST	19,000	0.5	-	VERTICAL	1,750	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP. PREVIOUSLY EF-1 OR EF-HOPE.
EF-1-10	COMPANY STORE RESTROOM	2010	BROAN	S90UE	-	-	120	-	-	1.1	-	-	-	-	-	80	0.125	-	-	-	PROP.	-	0.6	-	-	MOUNTED INSIDE THE PLENUM OF THE RESTROOM, BUT DUCTED VIA THE WALL TO THE OUTSIDE FACING THE BAY DOCKS. INSUFFICIENT DATA.
EF-1-11	CIP ROOM	2011	GREENHECK	TAUB-30H-50	-	-	460	60	3	-	-	-	5	-	AXIAL UPBLAST	11,500	0.3	-	VERTICAL	-	TUBE	-	-	650	-	ROOF MOUNTED
EF-2-11	WEST LAB & OFFICE	2011	GREENHECK	G-070-D	-	-	115	60	1	-	-	-	0.33	-	CENTRI.	200	0.25	-	VERTICAL	-	TUBE	-	-	250	-	ROOF MOUNTED
RH-1	CIP CONTROL ROOM	2011	GREENHECK	RH-24X24	-	-	-	-	-	-	-	-	-	AXIAL UPBLAST	300	0.25	-	4-WAY	-	-	-	-	125	-	ROOF MOUNTED	
EF-80	LINE 7 SHEETING ROOM	2013	GREENHECK	20-BISW-21-10-1	13955579 14K	1135802	-	-	-	-	-	-	1.915	-	UPBLAST	8,500	-	-	VERTICAL	-	-	-	-	-	-	ROOF MOUNTED. LOCATED ON THE OVEN ROOF ADJACENT TO MAU-10-93.
EF-82	LINE 6 SAUCE COOKING @ SAUCE ROOM	2013	GREENHECK	20-BISW-21-10-1	13955579 14K	1135889	-	-	-	-	-	-	1.915	-	UPBLAST	8,500	-	-	VERTICAL	-	-	-	-	-	-	ROOF MOUNTED. LOCATED ON THE PROCESS ROOF UNDER RMAU-15.
EF-1-14	JANITOR CLOSET	2014	GREENHECK	SP-B70	-	-	115	60	1	-	-	-	FRAC	-	ODP	50	0.25	-	VERTICAL	-	CABINET	-	1.5	10	-	LOCATED IN THE PLENUM ABOVE THE JANITOR CLOSET AT THE BREAKROOM AREA.
EF-2-14	LOCKER ROOMS	2014	GREENHECK	GB-101	-	-	115	60	1	-	-	-	0.33	-	DOWNBLAST	1,050	0.5	-	VERTICAL	-	TEFC	-	13.8	115	-	ROOF MOUNTED
EF-3-14	PROCESS MEZZANINE	2014	GREENHECK	TAUB-30H-50-X	12091009 1006	1032763	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	INSUFFICIENT DATA. TO BE VERIFIED.
EF-4-14	SAUCE WASHDOWN ROOM	2014	GREENHECK	CUBE-420-75	14154478 15F	-	-	-	-	-	-	-	7.5	-	UPBLAST	19,112	1	-	VERTICAL	565	-	-	-	-	-	ROOF MOUNTED/ MTR. OUT OF AIR STREAM
EF-81	LOWER LEVEL BLEACH ROOM	2016	GREENHECK	CUBE-099-3	-	-	-	-	-	-	-	-	-	-	UPBLAST	1,000	-	-	VERTICAL	-	-	-	-	-	-	LOCATED ON THE ROOF OF THE BLEACH ROOM NORTH OF RTU-5-16.