

EXHAUST FANS SCHEDULE - PART 1 OF 2

TYPICAL DESIGN CONDITIONS:

SUMMER = 91°F / 74°F

WINTER = 7°F

UNIT NO.	SERVICE AREA	YEAR INSTALLED	MANUFACTURER	MODEL NO.	SERIAL NO.	NESTLÉ TAG NO.	ELECTRICAL							MECHANICAL										NOTES			
							VOLT	HZ	PH.	FLA	MCA	MOP	HP	RPM	TYPE	AIRFLOW (CFM)	STATIC PRESSURE EXTERNAL (IN. W.C.)	TOTAL (IN. W.C.)	FAN TYPE	FAN RPM	MOTOR TYPE	DRIVE	SOUND POWER (SONES)		OPERATING WEIGHT (LBS.)	ROOF OPENING (IN. X IN.)	
EF-1-93	LOW BAY DOCK OFFICE TOILET	1993	LOREN COOK	ACED-120-C10D	-	-	120	-	-	4.4	-	0.17	-	-	-	854	0.375	-	-	-	-	100	25x25	-			
EF-3-93	LINES 4 & 5 PACKAGING	1993	HARTZELL	31-24-WI3	-	-	460	60	3	-	-	1.5	1,800	AXIAL	6,000	0.5	-	-	DUCT	1,350	TEFC	STL BELT	-	300	-	LOCATED ON MEZZANINE, DISCHARGE TO PACKAGING STORAGE, TO BE VERIFIED.	
EF-5-93	EAST MAINTENANCE SHOP	1993	HARTZELL	63-36-LJ3	-	-	460	60	3	3.4	-	2	1,800	UPBLAST	13,000	0.375	-	-	VERTICAL	1,052	TEFC	BELTED GALV	-	266	50x50	VERTICAL FAN ON ROOF	
EF-6-93	SAUCE ROOM @ ENTRANCE	1993	HARTZELL	70-42-WL5	-	-	460	60	3	13.2	16.6	-	5	1,750	-	19,000	0.5	-	-	-	TEFC	-	750	55½x55½	ALUM. FAN ON ROOF & EPOXY COATING		
EF-7-93	ENGINE ROOM EMERGENCY EXHAUST	1993	HARTZELL	63-44-LL3	-	-	460	60	3	7.6	-	-	5	1,800	UPBLAST	20,000	0.75	-	-	VERTICAL	1,010	TEAO	BELTED GALV	-	491	61½x61½	VERTICAL FAN ON ROOF, ALSO OPPER. MOTOR DAMPERS IN INTAKE AIR DUCTS.
EF-8-93	ENGINE ROOM EMERGENCY EXHAUST	1993	HARTZELL	63-44-LL3	-	-	460	60	3	7.6	-	-	5	1,800	UPBLAST	20,000	0.75	-	-	VERTICAL	1,010	TEAO	BELTED GALV	-	491	61½x61½	VERTICAL FAN ON ROOF, ALSO OPPER. MOTOR DAMPERS IN INTAKE AIR DUCTS.
EF-9-93	WEST MAINTENANCE SHOP	1993	HARTZELL	63-32-LI3	-	-	460	60	3	2.6	-	-	1.5	1,800	UPBLAST	10,000	0.375	-	-	VERTICAL	1,189	TEAO	BELTED GALV	-	245	43¾x43¾	ROOF MOUNTED
EF-10-93	STOCKROOM	1993	HARTZELL	69-12-WG3	-	-	460	60	3	1.0	-	-	0.75	1,800	UPBLAST	1,400	0.5	-	-	VERTICAL	2,650	TEFC	STL BELT	-	160	23¾x23¾	ROOF MOUNTED/ MTR. OUT OF AIR STREAM
EF-11-93	STOCKROOM	1993	HARTZELL	63-28-LG3	-	-	460	60	3	2.6	-	-	0.75	1,800	UPBLAST	6,000	0.375	-	-	VERTICAL	1,165	TEFC	BELTED GALV	-	160	43¾x43¾	ROOF MOUNTED
EF-12-93	CC1 DRY INGREDIENTS	1993	HARTZELL	63-36-LJ3	-	-	460	60	3	3.4	-	-	2	1,800	UPBLAST	13,000	0.375	-	-	VERTICAL	1,057	TEAO	BELTED GALV	-	270	50x50	ROOF MOUNTED
EF-14-93	SAUCE ROOM @ SOUTHEAST CORNER	1993	HARTZELL	70-42-WL5	-	-	460	60	3	13.2	16.6	-	5	1,750	-	19,000	0.5	-	-	-	TEFC	-	750	55½x55½	ALUM. FAN ON ROOF & EPOXY COATING		
EF-15-93	CIP ROOM	1993	HARTZELL	70-16-WH3	-	-	460	60	3	2.6	-	-	1	1,800	UPBLAST	3,000	0.5	-	-	VERTICAL	2,518	TEFC	AL BELT	-	160	27¾x27¾	ALUM. FAN ON ROOF & EPOXY COATING
EF-20-93	BOILER ROOM & FOAM ROOM	1993	HARTZELL	70-42-WL5	-	-	460	60	3	13.2	16.6	-	5	1,750	-	19,000	0.5	-	-	-	TEFC	-	750	55½x55½	ALUM. FAN ON ROOF & EPOXY COATING		
EF-22-93	TOILET EXHAUST @ FRONT OFFICE	1993	LOREN COOK	ACED-90C15DL	-	-	120	60	-	-	-	-	0.125	-	UPBLAST	371	0.375	-	-	VERTICAL	-	-	-	-	19x19	ROOF MOUNTED WITH EXHAUST DUCTS TO MEN'S & WOMEN'S OFFICE RESTROOMS.	
EF-23-93	LAB EXHAUST @ FRONT OFFICE	1993	LOREN COOK	ACEB-150C3B	-	-	460	60	3	-	-	-	0.25	-	UPBLAST	1,485	0.5	-	-	VERTICAL	-	-	-	-	26¾x26¾	ROOF MOUNTED. CURRENTLY NOT IN USE (TO BE VERIFIED).	
EF-32-93	SANITATION @ INEDIBLE DOCK (DOWNSTAIRS)	1993	ILG	SQRD-0100A	-	-	-	-	-	-	-	-	-	-	-	100	-	-	-	HORIZO.	-	-	-	-	-	WALL MOUNTED. THRU WALL VENTILATION FAN.	
EF-33-93	L5 OVEN EXHAUST STACK	1993	NEW YORK BLOWER	PLR-18-CW UB	-	-	460	60	3	-	-	-	7.5	-	CENTRI.	5,400	5	-	-	VERTICAL	-	-	-	-	1,250	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP	
EF-34-93	L5 OVEN EXHAUST STACK	1993	NEW YORK BLOWER	PLR-12-CW UB	-	-	460	60	3	-	-	-	3	-	CENTRI.	2,200	5	-	-	VERTICAL	-	-	-	-	1,000	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP	
EF-35-93	L5 OVEN EXHAUST STACK	1993	NEW YORK BLOWER	PLR-12-CW UB	-	-	460	60	3	-	-	-	3	-	CENTRI.	2,200	5	-	-	VERTICAL	-	-	-	-	1,000	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP	
EF-36-93	L5 OVEN EXHAUST STACK	1993	NEW YORK BLOWER	PLR-12-CW UB	-	-	460	60	3	-	-	-	3	-	CENTRI.	2,200	5	-	-	VERTICAL	-	-	-	-	1,000	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP	
EF-37-93	L5 OVEN EXHAUST STACK	1993	NEW YORK BLOWER	PLR-12-CW UB	-	-	460	60	3	-	-	-	3	-	CENTRI.	2,200	5	-	-	VERTICAL	-	-	-	-	1,000	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP	
EF-38-93	L5 OVEN INFEED & DISCHARGE HOODS	1993	LOREN COOK	VCR-180V6B	-	-	460	60	3	-	-	-	0.75	-	-	3,600	0.5	-	-	VERTICAL	-	-	-	-	120	30¾x30¾	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-39-93	L5 OVEN INFEED & DISCHARGE HOODS	1993	LOREN COOK	VCR-180V6B	-	-	460	60	3	-	-	-	0.75	-	-	3,600	0.5	-	-	VERTICAL	-	-	-	-	120	30¾x30¾	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-40-93	KEY CONVEYOR HOOD	1993	LOREN COOK	VCR-120V2B	-	-	120	60	-	-	-	-	0.167	-	-	475	0.25	-	-	VERTICAL	-	-	-	-	86	20x20	LOCATED ON ROOF ABOVE FREEZER INFEED.
EF-1-95	L4/5 FREEZER MEZZ @ OVEN MEZZ	1995	HARTZELL	63-36-LJ3	9504854	-	460	60	3	3.4	-	-	2	1,800	UPBLAST	15,080	0.125	-	-	VERTICAL	1,052	TEFC	BELTED GALV	-	266	42x42	VERTICAL FAN ON ROOF. PRDP PAT: 1317, DATE OF MANUFACTURE: 6/8/95. FR: 145T, 5446-15V-UTL-FAN-050190
EF-1-96	ENGINE ROOM EMERGENCY EXHAUST	1996	LOREN COOK	54EU12B	-	-	460	60	3	-	-	-	7.5	-	UPBLAST	36,000	-	0.25	-	VERTICAL	620	PROP	-	-	-	-	VERTICAL FAN ON ROOF
EF-2-96	ENGINE ROOM EMERGENCY EXHAUST	1996	LOREN COOK	60S11B	-	-	460	60	3	-	-	-	5	-	UPBLAST	36,000	-	0.25	-	VERTICAL	360	PROP	-	-	-	-	VERTICAL FAN ON ROOF
EF-3-96	ENGINE ROOM EMERGENCY EXHAUST	1996	LOREN COOK	54EU12B	-	-	460	60	3	-	-	-	7.5	-	UPBLAST	36,000	-	0.25	-	VERTICAL	620	PROP	-	-	-	-	VERTICAL FAN ON ROOF
EF-5-96	ENGINE ROOM VENT	1996	LOREN COOK	24LSUE	-	-	120	60	1	-	-	-	0.25	-	UPBLAST	3,500	-	0.125	-	VERTICAL	855	PROP	-	-	-	-	ROOF MOUNTED
EF-6-96	ENGINE ROOM VENT	1996	LOREN COOK	24LSUE	-	-	120	60	1	-	-	-	0.25	-	UPBLAST	3,500	-	0.125	-	VERTICAL	855	PROP	-	-	-	-	ROOF MOUNTED
EF-7-96	HOOD VENTING @ WEST MAINTENANCE SHOP	1996	LOREN COOK	24LSUE	-	-	460	60	3	-	-	-	1.5	-	UPBLAST	5,700	-	0.5	-	VERTICAL	1,475	PROP	-	-	-	-	ROOF MOUNTED
EF-8-96	PROCESS MEZZANINE	1996	LOREN COOK	36LSU	-	-	460	60	3	-	-	-	1	-	UPBLAST	10,700	-	0.125	-	VERTICAL	510	PROP	-	-	-	-	ROOF MOUNTED
EF-15-96	BATTERY CHARGING @ RECEIVING DOCK	1996	LOREN COOK	100R2B	-	-	120	60	1	-	-	-	0.167	-	UPBLAST	600	-	0.125	-	VERTICAL	1,215	PROP	-	-	-	-	ROOF MOUNTED
EF-19-96	LINES 6 & 7 WASHDOWN ROOM (DOWNSTAIRS)	1996	S&P USA	HREBC30	-	-	460	60	3	-	-	-	0.5	-	UPBLAST	4,594	-	0.25	-	VERTICAL	780	PROP	-	-	-	-	ROOF MOUNTED. FORMERLY STANLEY FANS.
EF-20-96	WEST MAINTENANCE SHOP	1996	LOREN COOK	100R2B	-	-	120	60	1	-	-	-	0.167	-	UPBLAST	770	-	0.125	-	VERTICAL	1,600	PRV	-	-	-	-	WALL MOUNTED ABOVE EXIT DOOR S4 @ WEST MAINTENANCE SHOP (?).
EF-21-96	QA LAB	1996	LOREN COOK	70R15DH	-	-	120	60	1	-	-	-	0.05	-	UPBLAST	200	-	0.125	-	VERTICAL	1,550	PRV	-	-	-	-	ROOF MOUNTED. TO BE VERIFIED.
EF-22-96	LINE 6 OVEN AREA (OVEN CIP TANKS)	1996	S&P USA	HREBC30	-	-	460	60	3	-	-	-	0.5	-	UPBLAST	4,594	-	0.25	-	VERTICAL	780	PROP	-	-	-	-	ROOF MOUNTED. FORMERLY STANLEY FANS.
EF-23-96	LINE 6 & 8 OVEN ROOM EXHAUST	1996	NEW YORK BLOWER	213	-	-	460	60	3	-	-	-	3	-	UPBLAST	3,200	-	1.5	-	VERTICAL	2,569	TUBE	-	-	-	-	ROOF MOUNTED. TO BE VERIFIED.
EF-24-96	L6 OVEN EXHAUST STACK	1996	NEW YORK BLOWER	182	-	-	460	60	3	-	-	-	7.5	-	CENTRI.	5,400	-	5	-	VERTICAL	2,227	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-25-96	L6 OVEN EXHAUST STACK	1996	NEW YORK BLOWER	182	-	-	460	60	3	-	-	-	7.5	-	CENTRI.	5,400	-	5	-	VERTICAL	2,227	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-26-96	L6 OVEN EXHAUST STACK	1996	NEW YORK BLOWER	182	-	-	460	60	3	-	-	-	7.5	-	CENTRI.	5,400	-	5	-	VERTICAL	2,227	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-27-96	L6 OVEN EXHAUST STACK	1996	NEW YORK BLOWER	182	-	-	460	60	3	-	-	-	7.5	-	CENTRI.	5,400	-	5	-	VERTICAL	2,227	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-28-96	L6 OVEN EXHAUST STACK	1996	NEW YORK BLOWER	182	-	-	460	60	3	-	-	-	7.5	-	CENTRI.	5,400	-	5	-	VERTICAL	2,227	TUBE	-	-	-	-	650°F HIGH TEMP. CONSTR./470°F OPER. TEMP
EF-29-96	L6 OVEN DISCHARGE HOOD EXHAUST	1996	NEW YORK BLOWER	213	-	-	460	60	3	-	-	-	3	-	UPBLAST	3,200	-	1.5	-	VERTICAL	2,569	TUBE	-	-	-	-	ROOF MOUNTED
EF-41-96	BATTERY CHARGING @ HIGH BAY DOCK	1996	LOREN COOK	100R2B	-	-	120	60	1	-	-	-	0.167	-	UPBLAST	600	-	0.125	-	VERTICAL	1,215	PROP	-	-	-	-	ROOF MOUNTED
EF-42-96	BREAKROOM AREA	1996	LOREN COOK	150R2B	-	-	120	60	1	-	-	-	0.167	-	UPBLAST	1,650	-	0.125	-	VERTICAL	850	PROP	-	-	-	-	ROOF MOUNTED
EF-44-96	LINES 6 & 7 PACKAGING MEZZANINE	1996	HARTZELL	31-24-WK3	-	-	460	60	3	-	-	-	0.167	-	UPBLAST	9,950	-	0.5	-	VERTICAL	1,940	PROP	-	-	-	-	ROOF MOUNTED
EF-46-96	LOWER LEVEL RESTROOMS	1996	LOREN COOK	70R15DL	-	-	120	60	1	-	-	-	0.05	-	UPBLAST	95	-	0.2	-	VERTICAL	1,720	PRV	-	-	-	-	ROOF MOUNTED