



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name :	EF-52 sanitation tanks	Organization :	EF-52 sanitation tanks
Status :	Pending	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Tyler Youells
Open :	05/12/2021 - Tyler Youells - National TAB	Description:	Fan is running but does not seem to run at full speed. There is a belt missing, but the remaining belt is tight. The fan is not strong enough to raise the gravity dampers on the exterior of the fan so no air is being exhausted. Unit is likely interlocked with mau 6-04. Unit must be traversed with a lift

Project RFI File Details

- 1. [Open](#) File.jpg

Project RFI Response Details

- 05/27/2021 National TAB - JOE HERTENSTEIN
 - FACILITIES TEAM TO REVIEW FOR MAINTENANCE