



## Nestle (Mt Sterling, KY)

### Project RFI Information

<b>Issue Name :</b>	EF-5A L5 wash down	<b>Organization :</b>	EF-5A L5 wash down
<b>Status :</b>	Pending	<b>Assigned To :</b>	National TAB - JOE HERTENSTEIN
<b>Shared To :</b>		<b>Created :</b>	Tyler Youells
<b>Open :</b>	05/12/2021 - Tyler Youells - National TAB	<b>Description:</b>	Unit disconnect is off. Fan is for wash down cycles only. Did someone forget to turn unit back on or there a problem with unit?

#### Project RFI File Details

- 1. [Open](#) File.jpg

#### Project RFI Response Details

- **05/27/2021** National TAB - JOE HERTENSTEIN
  - FACILITIES TEAM TO REVIEW FOR MAINTENANCE
- **05/19/2021** National TAB - Alec Lewis
  - Believes unit was forgotten to turn on. Send to facilities to review this unit and respond.