



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name :	EF 30-96 NOT SCHEDULED	Organization :	EF 30-96 NOT SCHEDULED
Status :	Pending	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Tyler Youells
Open :	05/12/2021 - Tyler Youells - National TAB	Description:	Unit not running. Disconnect is on. Fan and motor spin freely. Unit is not listed on EF schedule

Project RFI File Details

- 1. [Open](#) File.jpg

Project RFI Response Details

- **05/27/2021** **National TAB - JOE HERTENSTEIN**
 - FACILITIES TEAM TO REVIEW FOR MAINTENANCE
- **05/19/2021** **National TAB - Alec Lewis**
 - Facilities needs to review- unsure of use/intent for this fan. Believes it may be line 8 oven exhaust. Appears to have a newer motor, but not currently running. Labeled as EF-30 on drawing