



## Nestle (Mt Sterling, KY)

### Project RFI Information

**Issue Name :** EF 36-93 OVEN L5    **Organization :** EF 36-93 OVEN L5  
**Status :** Pending    **Assigned To :** National TAB - JOE HERTENSTEIN  
**Shared To :**    **Created :** Tyler Youells  
**Open :** 05/12/2021 - Tyler Youells - National TAB    **Description:** Fan not running. Disconnect is on and motor spins freely. Other EFs for L5 are running. There may be an issue with the fan/motor

Project RFI File Details

- 1. [Open](#) File.jpg

Project RFI Response Details

- **05/27/2021**    **National TAB - JOE HERTENSTEIN**
  - FACILITIES TEAM TO REVIEW FOR MAINTENANCE
- **05/19/2021**    **National TAB - Alec Lewis**
  - Maintenance needs to review. Fan not running.