



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name :	MAU 8-93 CIP ROOM	Organization :	MAU 8-93 CIP ROOM
Status :	Pending	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Tyler Youells
Open :	05/12/2021 - Tyler Youells - National TAB	Description:	Unit not running. disconnect is on. motor appears to not have run in a very long time and unit is in poor physical condition.

Project RFI File Details

1. [Open](#) MUA_8_93.jpg

Project RFI Response Details

- **05/20/2021** **National TAB - Tyler Youells**
 - Facilities said unit was started up not too long ago, but unit is not running. Looks like the contacted is tripped. See pic. May indicate a larger problem with the motor or blower.
 1. [Open](#) File.jpg
- **05/19/2021** **National TAB - Alec Lewis**
 - Facilities knows it's in bad condition, Scott said he got it running the other day. Serves the CIP room (clean in place).