



## Nestle (Mt Sterling, KY)

### Project RFI Information

<b>Issue Name :</b>	SF 1,3,4-06 OVEN MEZZ	<b>Organization :</b>	SF 1,3,4-06 OVEN MEZZ
<b>Status :</b>	Pending	<b>Assigned To :</b>	National TAB - JOE HERTENSTEIN
<b>Shared To :</b>		<b>Created :</b>	Tyler Youells
<b>Open :</b>	05/12/2021 - Tyler Youells - National TAB	<b>Description:</b>	Supply fans serve oven Mezz. Fans are running but the dampers are stuck mostly shut not allowing air into the mezz.

#### Project RFI File Details

- 1. [Open](#) File.jpg

#### Project RFI Response Details

- **05/27/2021 National TAB - JOE HERTENSTEIN**
  - FACILITIES TEAM TO REVIEW F. OR MAINTENANCE. FAN IS IN PRETTY BAD SHAPE
- **05/27/2021 National TAB - JOE HERTENSTEIN**
  - FACILITIES TEAM TO REVIEW FOR MAINTENANCE
- **05/20/2021 National TAB - Tyler Youells**
  - 1-06 is actually no longer running. Motor bracket is no longer secured and motor sits sideways. Belt is gone