



Nestle (Mt Sterling, KY)

Project RFI Information

Issue Name :	SF 14-93 L4 OVENS	Organization :	SF 14-93 L4 OVENS
Status :	Pending	Assigned To :	National TAB - JOE HERTENSTEIN
Shared To :		Created :	Tyler Youells
Open :	05/12/2021 - Tyler Youells - National TAB	Description:	Supply fan is running. Ductwork was separated and plastic trap was placed between it. SF served old style oven and is no longer needed

Project RFI File Details

1. [Open](#) File.jpg

Project RFI Response Details

- **05/20/2021 National TAB - JOE HERTENSTEIN**
 - Per Maintenance they believe these fans should be abandoned, removed, & capped. Currently fan is still running & they don't know why (Is it interlocked with another fan). They put plastic in duct to try to keep supply from entering the room.