



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-14 L6 OVEN STACK	Status :	Submitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No issues
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Is Fan interlocked with any other asset? if so, list:	L6 oven
When is fan used (application) and any specific time?	L6 oven
Make, Model, and Serial Number:	Unit data: SN: 2019-03785-02-4 MN: 17SST304 Motor 3hp 460 4.5a
Fan CFM:	Vel: 2863 10" Cfm 1575
Fan total pressure recorded.	