



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-59 BOILER ROOM	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Make: Greenheck Model: RBU-2L30-20 Serial: 04121349 SP: 0.46" Unable to safely access motor Avg fpm 42"X42" Avg fpm 849 10401 CFM
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	24/7
Make, Model, and Serial Number:	Make: Greenheck Model: RBU-2L30-20 Serial: 04121349 SP: 0.46" Unable to safely access motor Avg fpm 42"X42"
Fan CFM:	Avg fpm 849 10401 CFM