



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-6A / L6 MEDIUM HYGIENE WASHDOWN EXH	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fan only runs during L6 packaging Washdown
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	
Is Fan interlocked with any other asset? if so, list:	L6 packaging Washdown
When is fan used (application) and any specific time?	L6 packaging Washdown
Make, Model, and Serial Number:	Make:Cook Model:270ACRU Serial:063SH35891 2HP 2.7A 460V 1725RPM
Fan CFM:	