



Nestle (Mt Sterling, KY)

CheckList Information

Name :	MAU-1-11 / CIP ROOM	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Make: Greenheck Model: DGX-118-H32-DB Serial: 12095511 10 HP 460V 27.8 A 0.37" SP
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	24/7
Make, Model, and Serial Number:	Make: Greenheck Model: DGX-118-H32-DB Serial: 12095511 Unit Data: 10 HP 460V 27.8 A 0.37" SP