



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-11-93 STOCKROOM	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No visual issues. Motor has adjustable pulleys but no access to change.
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	No
When is fan used (application) and any specific time?	Heat evac
Make, Model, and Serial Number:	Hartzell 63-28-LG3 Serial:9302560-06 0.75hp 1800rpm 460V 1.6A Discharge pressure: 0.1"
Attach picture of asset.	
Fan CFM:	CFM: 6,525