



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-14-93 SAUCE ROOM @ SOUTHEAST CORNER	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Make: Hartzell Model:70-42-WL3 Serial:9802288-04-1 5HP 460V 13.2A 32" Dia Avg Fpm 2949 -1.29" SP
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA
Make, Model, and Serial Number:	Make: Hartzell Model:70-42-WL3 Serial:9802288-04-1 5HP 460V 13.2A 32" Dia
Fan CFM:	Avg Fpm 2949 -1.29" SP 32" DIA