



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-14-93 SAUCE ROOM @ SOUTHEAST CORNER	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Make: Hartzell Model:70-42-WL3 Serial:9802288-04-1 5HP 460V 13.2A 32" Dia Avg Fpm 2949 -1.29" SP
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA
Make, Model, and Serial Number:	Make: Hartzell Model:70-42-WL3 Serial:9802288-04-1 5HP 460V 13.2A 32" Dia Avg Fpm 2949 -1.29" SP 32" DIA
Fan CFM:	0