



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF 31-06 OVEN MEZZANINE	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	NO VISIBLE ISSUES So:-.341"
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	INTERLOCKED WITH OTHER OVEN MEZZ EX FANS. x3 TOTAL FANS CONNECTED BY SWITCH IN OVEN MEZZ BY DOOR
When is fan used (application) and any specific time?	USED TO EXHAUST AIR FROM OVEN MEZZ TYPICALLY ON 24/7
Make, Model, and Serial Number:	
Fan CFM:	