



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF 31-06 OVEN MEZZANINE	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	NO VISIBLE ISSUES SP:-.341"
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	INTERLOCKED WITH OTHER OVEN MEZZ EX FANS. x3 TOTAL FANS CONNECTED BY SWITCH IN OVEN MEZZ BY DOOR
When is fan used (application) and any specific time?	USED TO EXHAUST AIR FROM OVEN MEZZ TYPICALLY ON 24/7
Make, Model, and Serial Number:	GREENHECK, MN:RBUMO-3L36-50, SN:07KO3778
Fan CFM:	15100CFM.