



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-28-96 / L6 OVEN	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Unit has a lot of vibration. But no other visible issues
Make, Model, and Serial Number:	UNIT DATA: NYB Shop number: D02271-100 Size 182 PLR MOTOR 7.5 460 8.5 A
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan CFM:	Vel 3130 10" 1722 cfm
Fan total pressure recorded.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Is Fan interlocked with any other asset? if so, list:	L6 oven
When is fan used (application) and any specific time?	L6 oven