



Comfort. Under control.

Nestle (Mt Sterling, KY)

CheckList Information

Name : EF-26-06 / L4 OVEN EXHAUST STACK **Status :** NotSubmitted
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.

Discharge cover panel not secured.

- [Open](#) File.jpg

Make, Model, and Serial Number:

Unit data: B05825-100 Size: 174LS Motor: 3 ho 460 4.5A

Attach picture of asset.

Yes

- [Open](#) File.jpg

Fan CFM:

Vel:2558 10" Cfm: 1407

Fan total pressure recorded.

Yes

- [Open](#) File.jpg

Is Fan interlocked with any other asset? if so, list:

L4 oven

When is fan used (application) and any specific time?

L4 oven