



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF 18-06 L4 OVEN ROOM	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	1 drop. No visible issues
Make, Model, and Serial Number:	GREENHECK, RBUMO-2H30-15, OADO4371 (WARN TAG)
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan CFM:	7987CFM Sp:-.220"
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	Not known
When is fan used (application) and any specific time?	Venting the oven room. Typically 24/7