



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	EF-5A / L5 MEDIUM HYGIENE WASHDOWN EXH	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Never witnessed fan running
Attach picture of asset.	Yes
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
Fan total pressure recorded.	
Is Fan interlocked with any other asset? if so, list:	L5 Washdown Cycle
When is fan used (application) and any specific time?	L5 Washdown cycle
Make, Model, and Serial Number:	Make:Cook Model: 245 ACRU 245R8B Serial: 063SG90629-00 1.5HP 460V 1725RPM 2.7A
Fan CFM:	