



Nestle (Mt Sterling, KY)

CheckList Information

Name :	NH3-EEF-L8-A	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fan only runs during emergency use
Make, Model, and Serial Number:	Make:Greenheck Model:VK-H-15-A50-X Serial:11604650
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan CFM:	NA
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	L8 infeed
When is fan used (application) and any specific time?	L8 infeed