



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-7A / L7 MEDIUM HYGIENE WASHDOWN EXH	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fan only runs during L7 packaging Washdown
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	
Is Fan interlocked with any other asset? if so, list:	L7 Washdown
When is fan used (application) and any specific time?	L7 Washdown
Make, Model, and Serial Number:	Make:Cook Model:300ACRU Serial:063SH35891 3HP 1750RPM 460V 4.3A
Fan CFM:	