



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-6-08 / LOCKER, TOILETS & AIR TUNNEL	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fan on roof. Serves multiple rooms
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	No
When is fan used (application) and any specific time?	24-7 exhaust for locker rooms etc
Make, Model, and Serial Number:	COOK, 180-ACF-18005B, 0835932274
Fan CFM:	1413 CFM SP:-0.301"