



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-4-14 / SAUCE WASHDOWN ROOM	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	Fan does not run
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	No
Is Fan interlocked with any other asset? if so, list:	NA
When is fan used (application) and any specific time?	NA
Make, Model, and Serial Number:	Make: Greenheck Model: UBE-120-75 Serial: 14154478 BALDOR 7.5 HP 460V 9.4A 1770 RPM
Fan CFM:	