



Nestle (Mt Sterling, KY)

CheckList Information

Name :	EF-12-93 CC1 DRY INGREDIENTS	Status :	NotSubmitted
Assigned Organization :	National TAB	Asset :	
Requesting Organization :	National TAB		

CheckList Item Details

Observe Unit to ensure operational and no visual issues. If any observed, comment. Note # of duct drops.	No visual issues.
Attach picture of asset.	Yes
<ul style="list-style-type: none"> • Open File.jpg 	
Fan total pressure recorded.	Yes
Is Fan interlocked with any other asset? if so, list:	Should run with ff in same area
When is fan used (application) and any specific time?	Heat evac in summer
Make, Model, and Serial Number:	Unit data: Hartzell 63-36-LJ3 9302560-07-A 2 HP 460 2.8A Discharge 0.388"
Fan CFM:	cfm: 12,225