



## Nestle (Mt Sterling, KY)

### CheckList Information

<b>Name :</b>	RMAU-9 Mix Room North	<b>Status :</b>	NotSubmitted
<b>Assigned Organization :</b>	National TAB	<b>Asset :</b>	
<b>Requesting Organization :</b>	National TAB		

### CheckList Item Details

OBSERVE UNIT TO ENSURE OPERATIONAL & NO VISUAL ISSUE. IF ANY COMMENT . NOTE # OF SUPPLY & RETURN DUCTS	2 supply and 2 returns
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
VERIFY OA DAMPER POSITION & NOTE APPROXIMATE OPEN AMOUNT(VISUAL). ATTATCH PICTURE	Closed
DOES UNIT HAVE EXHAUST/RELIEF FANS AND HOW MANY	Yes, 4 relief fans
NO RELIEF/ EXHAUST FANS OPERATIONAL WHEN TESTING	Yes
FAN TOTAL PRESSURE RECORDED	Yes
FAN VFD SPEED	No
<ul style="list-style-type: none"> <li>• <a href="#">Open</a> File.jpg</li> </ul>	
OA DAMPER POSITION(CONTROLS OUTPUT)	Yes