

GRILLS, REGISTERS, AND DIFFUSERS SCHEDULE

| TAG | DESCRIPTION | FACE SIZE | MATERIAL | FINISH | MOUNTING | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | NOTES |
|-----|-----------------------------------|---------------|----------|--------|----------------|--------------|--------------|------------------|--------------|--|
| | | | | | | | | MANUFACTURER | MODEL | |
| CD1 | PERFORATED CEILING DIFFUSER | 24" X 24" | ALUMINUM | WHITE | LAY-IN CEILING | GC | GC | NAILOR | 4320A TYPE L | PROVIDE INTEGRAL OBD |
| CD3 | PERFORATED CEILING DIFFUSER | 24" X 12" | ALUMINUM | WHITE | LAY-IN CEILING | GC | GC | NAILOR | 4320A TYPE L | PROVIDE INTEGRAL OBD, REMOVE 4-WAY DEFLECTOR |
| CD4 | PERFORATED CEILING DIFFUSER | 12" X 12" | ALUMINUM | WHITE | GYP CEILING | GC | GC | NAILOR | 4320A TYPE S | PROVIDE INTEGRAL OBD |
| ER1 | PERFORATED CEILING EXHAUST | 12" X 12" | ALUMINUM | WHITE | GYP CEILING | GC | GC | NAILOR | 4330R TYPE S | PROVIDE INTEGRAL OBD |
| RG1 | PERFORATED CEILING RETURN | 48" X 24" | ALUMINUM | WHITE | LAY-IN CEILING | GC | GC | NAILOR | 4330R TYPE L | |
| RG2 | PERFORATED CEILING RETURN | 48" X 24" | ALUMINUM | WHITE | GYP CEILING | GC | GC | NAILOR | 4330R TYPE S | |
| SR1 | ADJUSTABLE TURBO NOZZLE | SEE NECK SIZE | ALUMINUM | WHITE | WALL | GC | GC | AIR CONCEPTS | ANR-14 | PROVIDE FACE-ACCESSIBLE OBD |
| SR2 | DOUBLE DEFLECTION SUPPLY REGISTER | SEE NECK SIZE | ALUMINUM | WHITE | WALL | GC | GC | NAILOR | 51DH | PROVIDE INTEGRAL OBD |

SANITIZING EQUIPMENT SCHEDULE

| TAG | COUNT | DESCRIPTION | FURNISH ED BY | INSTALLE D BY | BASIS FOR DESIGN | | REMARKS |
|------|-------|--------------------------------|---------------|---------------|-------------------------|--------------|---|
| | | | | | MANUFACTURER | MODEL | |
| SB-1 | 2 | BATHROOM AIR PURIFICATION UNIT | TUV | GC | RGF ENVIRONMENTAL GROUP | BRU ASSEMBLY | SEE ELECTRICAL SHEETS FOR CONNECTION INFORMATION |
| SH-1 | 2 | HVAC AIR PURIFICATION UNIT | TUV | GC | RGF ENVIRONMENTAL GROUP | REME-HALO | SEE DETAIL 6/M700 FOR INSTALLATION INFORMATION. |
| SI-1 | 3 | ICE MACHINE TREATMENT SYSTEM | TUV | GC | RGF ENVIRONMENTAL GROUP | IMS-B-GA | SEE PLUMBING DRAWINGS FOR INSTALLATION INFORMATION. |

VIROGUARD SCHEDULE

| TAG | QUANTITY | DESCRIPTION | DUCT CONNECTION SIZE | FAN | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN MANUFACTURER |
|------|----------|---|----------------------|-----------------------|--------------|--------------|-------------------------------|
| VG-1 | 1 | VIROGUARD HOOD EXHAUST FAN ROOFTOP CONTAINMENT SYSTEM | 18" X 18" | CAPTIVE-AIRE DU240HFA | TDC | GC | ENVIROMATIC |

FAN SCHEDULE

| TAG | DRIVE TYPE | EXHAUST FLOW [CFM] | E.S.P. [in W.C.] | WEIGHT [lbs] | ELECTRICAL | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|------|------------|--------------------|------------------|--------------|-------------|----------|--------------|--------------|------------------|----------|--|
| | | | | | MOTOR POWER | V/P/H | | | MANUFACTURER | MODEL | |
| EF-1 | DIRECT | 3200 CFM | 1.20 in-wg | 400 | 3 HP | 208/3/60 | HS | GC | CAPTIVE-AIRE | DU240HFA | FURNISHED WITH DISCONNECT AND VENTED ROOF CURB |
| EF-2 | DIRECT | 150 CFM | 0.60 in-wg | 100 | 0.18 HP | 120/1/60 | HS | GC | CAPTIVE-AIRE | DR12HFA | FURNISHED WITH DISCONNECT, VARIABLE SPEED CONTROLLER, BACKDRAFT DAMPER AND ROOF CURB |

MAKEUP AIR UNIT SCHEDULE

| TAG | DESCRIPTION | AIRFLOW | | HEATING CAPACITY | | | | APPROXIMATE WEIGHT [lbs] | ELECTRICAL | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|-------|-----------------|-------------------|-------------------|------------------|--------------|------------------|-------|--------------------------|-------------|----------|--------------|--------------|------------------|--------------|--|
| | | SUPPLY FLOW [CFM] | E.S.P. [in. W.C.] | INPUT [MBH] | OUTPUT [MBH] | MAXIMUM TURNDOWN | EAT | | MOTOR POWER | V/P/H | | | MANUFACTURER | MODEL | |
| MAU-1 | MAKEUP AIR UNIT | 1950 | 0.80 | 225 | 220 | 12.5:1 | 11 °F | 650 | 2 HP | 208/3/60 | HS | GC | CAPTIVE-AIRE | A1-D.250-G10 | FURNISHED WITH DISCONNECT, ROOF CURB, SCREEN INTAKE, AND WASHABLE ALUMINUM FILTERS |

CONDENSING UNIT SCHEDULE

| TAG | DESCRIPTION | NOMINAL CAPACITY [TONS] | NUMBER OF COMPRESSORS | NUMBER OF CIRCUITS | REFRIGERANT TYPE | REFRIGERANT CHARGE | WEIGHT | ELECTRICAL | | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS |
|------|---------------------------------------|-------------------------|-----------------------|--------------------|------------------|--------------------|--------|------------|-------|----------|--------------|--------------|------------------|------------|-------------------------------|
| | | | | | | | | MOC | FLA | V/P/H | | | MANUFACTURER | MODEL | |
| CU-1 | WALK-IN COOLER REMOTE CONDENSING UNIT | -- | 1 | 1 | R-404A | | 200 | 15 A | 6.5 A | 208/3/60 | WCS | GC | HARFORD | PCL99MOP-3 | FURNISHED WITH WALK-IN COOLER |
| CU-2 | ICE MAKER - REMOTE CONDENSER | -- | 0 | 1 | R-404A | 11 lbs 7.4 oz | 100 | | | 120/1/60 | KES | GC | - | - | FURNISHED WITH ICE MAKER |
| CU-3 | ICE MAKER - REMOTE CONDENSER | -- | 0 | 1 | R-404A | 11 lbs 7.4 oz | 100 | | | 120/1/60 | KES | GC | - | - | FURNISHED WITH ICE MAKER |

KITCHEN HOOD SCHEDULE

| TAG | DESCRIPTION | MAX COOKING TEMP. | AIRFLOW [CFM] | SP [in. W.C.] | EXHAUST PLENUM | | | | PERFORATED SUPPLY PLENUMS | | | | | | | | | | NUMBER OF LIGHT FIXTURES | APPROXIMATE WEIGHT [lbs] | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS | |
|------|--|-------------------|---------------|---------------|----------------|-------|--------|----------|---------------------------|----------------------|---------------------|---------------|--------------|-------|--------------|---------------|-----|----------|--------------------------|--------------------------|--------------|--------------|------------------|--------------|--------------------|--|
| | | | | | DUCT COLLARS | | | | SP [in. W.C.] | SUPPLY PLENUM LENGTH | SUPPLY PLENUM WIDTH | MAU PLENUM | | | AC PLENUM | | | | | | | | MANUFACTURER | MODEL | | |
| | | | | | NO. | WIDTH | LENGTH | LENGTH | | | | AIRFLOW [CFM] | DUCT COLLARS | | DUCT COLLARS | | | | | | | | | | | |
| | | | | | | | | | | | | | NO. | WIDTH | LENGTH | AIRFLOW [CFM] | NO. | DIAMETER | | | | | | | | |
| HD-1 | TYPE I CANOPY HOOD WITH PERFORATED MAU AND AC SUPPLY PLENUMS | 600°F | 3200 | 0.86 | 2 | 10" | 15" | 14' - 3" | 4' - 3" | 0.2 | 15' - 3" | 22" | 1950 | 3 | 10" | 28" | 800 | 7 | 8" | 10 | 1200 | HS | GC | CAPTIVE-AIRE | 5424 ND-2-ACPS-P-F | MAT'L: 18 GA. TYPE 430 SS. PROVIDE WITH 16" TALL HE SS FILTERS, INTEGRAL UTILITY CABINET, ANSUL SYSTEM, DUCT COLLAR TEMPERATURE SENSOR, PREWIRE PACKAGE, SPARE FIRE SYSTEM DRY CONTACT, AND 4-POLE 20A CONTACTOR |

ROOFTOP UNIT SCHEDULE

| TAG | DESCRIPTION | NOMINAL CAPACITY [TONS] | EER | AIRFLOW | | | NET COOLING CAPACITY | | | | HEATING CAPACITY | | | # OF COMPRESSORS | # OF CIRCUITS | REFRIG. TYPE | REFRIG. CHARGE | APPROX. WEIGHT [lbs] | ELECTRICAL | | | FURNISHED BY | INSTALLED BY | BASIS FOR DESIGN | | REMARKS | |
|-------|--------------------------|-------------------------|-----|-------------|----------|----------------|----------------------|----------------|--------------|--------------------|------------------|--------------|--------------|------------------|---------------|--------------|----------------|----------------------|------------|------|--------|--------------|--------------|------------------|-------|---------|---|
| | | | | TOTAL [CFM] | OA [CFM] | ESP [in. W.C.] | TOTAL [MBH] | SENSIBLE [MBH] | EAT [DEG. F] | COND. EAT [DEG. F] | INPUT [MBH] | OUTPUT [MBH] | EAT [DEG. F] | | | | | | MOC | FLA | V/P/H | | | MANUFACTURER | MODEL | | |
| RTU-1 | KITCHEN ROOFTOP UNIT | 10 | 12 | 3500 | 500 | 0.8 | 119 | 75 | 76 | 66 | 91 | 180 | 144 | 60 | 2 | 2 | R-410A | 7.9/7.9 | 1350 | 50 A | 44.9 A | 208/3/60 | HES | GC | YORK | Z1120 | FURNISHED WITH COMP. ENTHALPY ECON., BAROMETRIC RELIEF, RET. SMOKE DETECTOR W/ REMOTE KEYED ANNUNCIATOR/RESET, M.O.D., MERV-8 FILTERS, CURB, HAIL GUARD, TOOLLESS HINGED ACCESS PANELS, DISCONNECT, & UNIT-MOUNTED CONVENIENCE RECEPTACLE |
| RTU-2 | DINING ROOM ROOFTOP UNIT | 7.5 | 12 | 3000 | 1000 | 0.8 | 92 | 59 | 79 | 68 | 93 | 180 | 144 | 51 | 2 | 2 | R-410A | 7.8/7.6 | 1300 | 50 A | 45.8 A | 208/3/60 | HES | GC | YORK | Z1090 | FURNISHED WITH COMP. ENTHALPY ECON., BAROMETRIC RELIEF, RET. SMOKE DETECTOR W/ REMOTE KEYED ANNUNCIATOR/RESET, M.O.D., MERV-8 FILTERS, CURB, HAIL GUARD, TOOLLESS HINGED ACCESS PANELS, DISCONNECT, & UNIT-MOUNTED CONVENIENCE RECEPTACLE |

Consultant:

NATIONAL
 ENGINEERING
 4635 Trueman Blvd, Suite 250
 Hilliard, Ohio 43026
 Phone: (614) 751-9610
 Fax: (614) 552-5240
 Contact: Andy Janosik
 (614) 328-2028
 ajanosik@nationalengineering.com

FOR CONSTRUCTION

PROFESSIONAL CERTIFICATION:
 I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A QUALY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND. LICENSE NO. 25610, EXPIRATION DATE: 08-27-2025.

COPYRIGHT 2023
 THIS DRAWING IS AN INSTRUMENT OF SERVICE AND AS SUCH REMAINS THE PROPERTY OF CHIPOTLE MEXICAN GRILL, INC.. PERMISSION FOR USE OF THIS DOCUMENT IS LIMITED AND CAN BE EXTENDED ONLY BY WRITTEN AGREEMENT WITH CHIPOTLE MEXICAN GRILL, INC..



CHIPOTLE MEXICAN GRILL, INC.
 PO BOX 182566
 COLUMBUS, OH 43218-2566
 TELEPHONE: (614) 318-2400
 INTERNET: WWW.CHIPOTLE.COM

AIR BALANCE SCHEDULE

| Tag | Supply Flow [CFM] | Return Flow [CFM] | Exhaust Flow [CFM] | Subtotal [CFM] |
|--------------------------|-------------------|-------------------|--------------------|----------------|
| EF-1 | 0 | 0 | 3200 | -3200 |
| EF-2 | 0 | 0 | 150 | -150 |
| MAU-1 | 1950 | 0 | 0 | 1950 |
| RTU-1 | 3500 | 3000 | 0 | 500 |
| RTU-2 | 3000 | 2000 | 0 | 1000 |
| Net Pressurization [CFM] | | | | 100 |

CONTROL FUNCTIONS

- A. THE MAIN COOKING EXHAUST FAN AND MAKE-UP AIR UNIT SHALL BE INTERLOCKED TO OPERATE TOGETHER. THIS CONTROL CIRCUIT IS ACTIVATED BY A SWITCH AND INCLUDES A FIRE PROTECTION OVERRIDE.
- B. THE TEMPERATURE IN EACH ZONE IS CONTROLLED BY SPACE TEMPERATURE SENSORS CONNECTED TO THE THERMOSTATS LOCATED IN THE OFFICE. ALL ZONES SHALL OPERATE WITH CONTINUOUS FAN OPERATION DURING OCCUPIED TIMES AND INTERMITTENTLY AS NEEDED TO MAINTAIN SET POINTS DURING UNOCCUPIED TIMES. OUTSIDE AIR DAMPERS SHALL BE OPEN CONTINUOUSLY WHEN EITHER IN OCCUPIED MODE OR WHEN THE HOOD SYSTEM IS ON AND SHALL BE CLOSED DURING UNOCCUPIED PERIODS.
- C. THE THERMOSTATS SHALL DETERMINE OCCUPIED/UNOCCUPIED STATUS BASED ON THE SCHEDULE IN THE ENERGY MANAGEMENT SYSTEM.

STORE NO.: 4545
 COCKEYSVILLE
 9701 YORK RD
 COCKEYSVILLE, MD 21030

Issue Record:
 12.22.2022 ISSUE FOR PERMIT
 10.27.2023 ISSUE FOR CONSTRUCTION

Revisions:

Drawn: AJJ
 Checked: AJJ

Project No:
 2201075

Contents:
 HVAC SCHEDULES

M600