

SQUARE DUCT TRAVERSE FORM

PROJECT Walgreens	SYSTEM York RTU ZT150N24R2B5GCB2R1
LOCATION New York City, New York	SERVICE _____
ALTITUDE 279 ft DENSITY -	FACTOR -

DUCT	REQUIRED	ACTUAL
S.P. 0.1462" TEMP 63 F	SCFM -	SCFM -
SIZE 20inX40in	FPM _____	FPM 598
AREA 5.56 ft^2	CFM _____	CFM 3323

DISTANCE FROM BOTTOM	POSITION	1	2	3	4	5	6	7	8	9	10	11	12
	1	403	496	536	526	588	498	520	530				
	2	517	484	522	541	529	597	532	577				
	3	405	429	503	536	626	514	546	607				
	4	595	543	639	533	534	580	583	546				
	5	695	704	618	697	635	679	707	702				
	6	817	79	801	825	761	822	773	821				
	7	459	474	433	540	593	839	789	803				
	8												
	9												
	10												
	11												
	12												
	13												
DISTANCE FROM DUCT EDGE													
VELOCITY SUB - TOTALS													

REMARKS: