



NATIONAL TAB
AIR DUCT LEAKAGE TEST SUMMARY



Tested: 7/10/2023

INTELLIGENCE

PROJECT: USACE Reset (Winterville, NC)
 ASSET: _____
 LEAKAGE CLASS 16
 SPECIFIED TEST PRESSURE (Pi) -2.0"
 DUCT CONSTRUCTION PRESSURE CLASS (Pc) A

DESIGN DATA				FIELD TEST DATA RECORD							
SUBJECT DUCT	SURFACE AREA IN FT ²	ALLOWABLE LEAKAGE		DIAMETER		PRESSURE "	ACTUAL % CFM / SF	ACTUAL CFM	DATE	PERFORMED BY	WITNESSED BY
		LIMIT %	CFM	ORIFICE	TUBE	DUCT					
		CFM / SF	(TEST SECTION)								
RETURN DUCT											
1	698	0.25	174.50	3.75	4	-2.01	0.0179	12.54	7/10/2023	SS	DS /Team
	698		174.50								

REMARKS

TAB TEAM: National TAB
 CONSTRUCTION TEAM: Team Construction NC

DATE: 7/10/2023