

PlanGrid Task Report - Jul 3, 2025

Prepared by Will Turnbough

Jul 3, 2025

Description

2 tasks in this report.

Contents

#47 [REFG 500] [NEW] WIC/WIF temperatures.	2
#44 [REFG 518] [NEW] Line sets installations.....	2

#47 [REFG 500] [NEW] WIC/WIF temperatures.

Status Pending	Start Date Sep 26, 2024
Type Planned Work	Created Sep 26, 2024 12:18 PM will@nationaltab.com
Description WIC door is reading 38 degrees Field piece temp reading is at 33 degrees inside WIC.	Last Updated Jun 26, 2025 3:44 PM

#44 [REFG 518] [NEW] Line sets installations.

Status Pending	Start Date Sep 25, 2024
Type Planned Work	Created Sep 26, 2024 12:18 PM will@nationaltab.com
Description Line sets contain excessive lengths (loop traps), are not routed properly, or are not properly insulated/secured.	Last Updated Jun 27, 2025 9:55 AM
