

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: Punchlist
Function: Test, Adjust, & Balance
Date: 02/26/2026
Completed By: National TAB

PROJECT

02-23-26 WAWA #6902 MARTINSBURG, WV

HEDGESVILLE RD & ROCK CLIFF RD

MARTINSBURG, WV 25403

Client

Wawa
260 West Baltimore Pike

Wawa, PA 19063

National TAB

Project: 02-23-26 WAWA #6902 MARTINSBURG, WV

Table Of Contents

Section	Page #
Remarks	3

Issue List

- RTU-2 Alarm



02-23-26 WAWA #6902 MARTINSBURG, WV

Project Issue Information

Issue Name : RTU-2 Alarm
Description : Unit is giving Alarm 147 for "Damper Feedback Loss".
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Open
Priority : Low **Asset Tag :** RTU2
Originated Date : 02/27/2026 - John Barresi - National TAB

Project Issue File Details

