



AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	870	883	420	396				
RTU-2	SALES	870	897	420	438				
RTU-3	BOH/KITCHEN	870	862	420	424				
RTU-4	STORAGE	100	98	100	98				
EF-1	MEN'S RR					600	572	600	572
EF-2	WOMEN'S RR					400	386	400	386
EF-3	HOOD					1350	1432	0	0
TOTALS		2710	2740	1360	1356	2350	2390	1000	958

HOODS ON

NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2710	2740
TOTAL EXHAUST	2350	2390
NET AIRFLOW	360	350

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.0101
SIDE	0.0055
REAR	0.0011
AVERAGE	0.0056

HOODS OFF

NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	1360	1356
TOTAL EXHAUST	1000	958
NET AIRFLOW	360	398

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.0041
SIDE	0.0066
REAR	0.0036
AVERAGE	0.0048

NOTES:

See issues list.