

PlanGrid Task Report - Jun 19, 2024

Prepared by Ian Fuller

Jun 19, 2024

Description

3 tasks in this report.

Contents

#3 [UNIT 164] Equipment gas piping.	2
#2 [UNIT 167] Condensate piping construction.....	4
#1 [UNIT 172] Filters to be changed.	5

#3 [UNIT 164] Equipment gas piping.

Status

Open

Start Date

Jun 17, 2024

Type

Planned Work

Created

Jun 17, 2024 4:49 PM
ianf@nationaltab.com

Description

Gas startups incomplete, or gas piping out is not constructed/supported per normal CFA specifications. Valves turned off, pipes not painted with aluminum base paint and zinc rust primer per plumbing specs.

Last Updated

Jun 18, 2024 3:23 PM

Photos



IMG_7521

Ian Fuller

Jun 18, 2024 3:23 PM

#2 [UNIT 167] Condensate piping construction.

Status
Open

Start Date
Jun 17, 2024

Type
Planned Work

Created
Jun 17, 2024 4:49 PM
ianf@nationaltab.com

Description
Equipment condensate piping or p-trap is not constructed per normal CFA specifications. Missing union on one side of p-trap.

Last Updated
Jun 18, 2024 3:23 PM

Photos



IMG_7522
Ian Fuller
Jun 18, 2024 3:23 PM

#1 [UNIT 172] Filters to be changed.

Status

Open

Start Date

Jun 17, 2024

Type

Planned Work

Created

Jun 17, 2024 4:49 PM
ianf@nationaltab.com

Description

Filters are dirty, damaged, not correct size, or are to be changed with extra set provided per specification. Construction filters installed in AC#2, mechanical will install final filters.

Last Updated

Jun 19, 2024 10:18 AM

Photos



IMG_7523

Ian Fuller

Jun 18, 2024 3:23 PM