

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: Punch Lst
Function: Test, Adjust, & Balance
Date: 02/24/2025
Completed By: National TAB

PROJECT

Kenton County School Ops Ctr (Independence, KY)

11800 Taylor Mill Rd

Independence, KY 41051

Client

Hudson Piping Inc.

836 Walnut St.

Dayton, KY 41074

National TAB

Project: Kenton County School Ops Ctr (Independence, KY)

Table Of Contents

| Section | Page # |
|------------|--------|
| Issue Data | 3 |

Issue List

- EF's Not Operational
- Return Grille 22
- VAV-15 No Diffusers
- VAV-16 Removed from Plans



Kenton County School Ops Ctr (Independence, KY)

Project Issue Information

Issue Name : EF's Not Operational
Description : Control wiring for EF's has not been completed.
Created By : National TAB **Assigned To :** National TAB - Nick Payne
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 02/18/2025 - Jordan Best - National TAB



Kenton County School Ops Ctr (Independence, KY)

Project Issue Information

Issue Name : Return Grille 22
Description : Return grille 22 is not installed.
Created By : National TAB **Assigned To :** National TAB - Nick Payne
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 02/18/2025 - Jordan Best - National TAB



Kenton County School Ops Ctr (Independence, KY)

Project Issue Information

Issue Name : VAV-15 No Diffusers
Description : Diffusers for VAV-15 have yet to be installed.
Created By : National TAB **Assigned To :** National TAB - Nick Payne
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 02/18/2025 - Jordan Best - National TAB



Kenton County School Ops Ctr (Independence, KY)

Project Issue Information

Issue Name : VAV-16 Removed from Plans
Description : Drawings were revised and VAV-16 has been removed from the plans. Its single diffuser was added to VAV-15.
Created By : National TAB **Assigned To :** National TAB - Nick Payne
Status : Open
Priority : Low **Asset Tag :**
Originated Date : 02/18/2025 - Jordan Best - National TAB